



ⓘ Discontinued

XPSAT3710 has not been replaced. Please contact your customer care centre for more information.

Main

Device short name	XPSAT
Range of product	Preventa
Safety use category	Instantaneous category 4 conforming to EN 954-1 Time delay category 3 conforming to EN 954-1

Complementary

[Us] rated supply voltage	230 V AC
Contacts type and composition	1 NC
Electrical connection	Screw clamp terminal
Number of safety circuits	3 NO for instantaneous 2 NO for time delayed
Pilot light	4 LED
Connector type	Terminal block

Environment

Ambient air temperature for operation	-14...130 °F
---------------------------------------	--------------

Contractual warranty

Warranty period	18 months
-----------------	-----------

Disclaimer: This documentation is not intended as a substitute for and is not to be used for determining suitability or reliability of these products for specific user applications